

Town of Weathersfield, VT
Lottery Lane Culvert
Contractor Plan holder list

March 23, 2022

Current Plan holder list:

Contractors

1. AS Clark & Sons (Archie Clark): arch24@myfairpoint.net
(Win Clark): asclarkandsons@gmail.com
2. Bazin Brothers Trucking (Jeff Marsden): jmarsden@bazinbrothers.com
3. Gurney Brothers Construction (Doug Gurney): dug@vermontel.net
4. Hunter Excavating (Hunter): hunterexprojects@gmail.com
(Bret): Hunterexvt@gmail.com
5. Northwoods Excavating, Inc. (Marry Ellen Parkman):
maryellen.northwoodsexcavating@gmail.com
6. J. Fenoff Siteworks (Josh Fenoff): JFenoffsiteworks@gmail.com
7. Daniels Construction (Matt Beldon): mbelden@neilhdaniels.com
8. Adams Trucking & Excavation (Buck Adams): adamsbuck@hotmail.com
9. Murphy & Son Construction: email listed did not work, called for correct email, no response

Suppliers

10. Contech (Glen Robie): glenn.robie@conteches.com
11. Lane Enterprises (Kent Wusterbarth): kwusterbarth@lane-enterprises.com

Town of Weathersfield, VT
Lottery Lane Culvert
Addendum #1

Addendum Date: March 2, 2022

The following items pertain to this Addendum:

1. The bid due date has been changed from March 17, 2022 to March 31, 2022 at 2:30pm.
2. The length of the box shall be 50' +/- 1' in length (49' to 51').
3. The length of the wingwalls shall be 8' +/- 1' in length (7' to 9').
4. The weirs of the box shall be aluminum, not concrete.
5. The estimated time frame for road closure shall be 30 days.
6. The on-site pre-bid meeting has been changed to March 15, 2022 at 9:30am.

REMINDER: All proposals are due to the Weathersfield Town Offices no later than 2:30pm on Thursday, March 31, 2022.

Town of Weathersfield, VT
Lottery Lane Culvert
Addendum #2

Addendum Date: March 22, 2022

The following items pertain to this Addendum:

1. The last day for contractors questions is March 25, 2022 at 6:00pm.
2. Addendum #3 shall be emailed out to bidders of record on Sunday, March 27, 2022. Contractors interested in receiving Addendum #3 in an email that did not attend the non-mandatory pre-bid meeting should email Everett Hammond at hammondeng@gmail.com by Friday, March 25th at 6:00pm to be added to the list.
3. Addendum #3 will also be posted on the Town Website on March 28, 2022.
4. Double nesting of guard rails was asked at the pre-bid meeting. This will not be necessary, as we will install a single guard rail over the box with the following additions to the guard rail posts. The 6" x 6" galvanized bearing plate described in item 18 shall be installed at elevation 97.00. After the guard rail and posts have been installed, the contractor shall form up a concrete base as follows centered over the new culvert. The form on each side of the road shall be 15' length x 3' wide x 15" thick with the top at elevation 98.00 and the bottom at elevation 96.75 (0.25" below the galvanized pads). The front edge shall be 8" in front of the posts. Total concrete = 2 sides x (15' x 3' x 1.25')/27 = 4.2 CY. Rebar shall be installed as follows: #4 rebar 8" on center length wise and 12" on center width wise. The top and sides of the concrete shall be sprayed with cur-n-seal upon stripping of the forms. The cost for the excavation, forming, rebar, concrete and labor will be considered part of the Guard Rail Anchor price listed in Item #20.
5. Toe wall grouting. A question was raised about this at the pre bid meeting. The toe wall that ends up with voids due to construction of the toe wall shall be outfitted with grout ports that can be used to fill with grout to fill the void. Any surface of the toe wall that will be in contact with the grout shall be coated with a concrete protectant prior to placing the grout. Other options may be acceptable if approved by the engineer during shop drawing review. The cost of this work shall be incidental to Item # 10; the cost of the box installation.
6. The contractor will need to submit proposed gravel sieves and proctor curve on the culvert material a minimum of 7 days prior to installation.
7. Soil compaction testing will be paid for by the Town.
8. The Public Bid opening of the RFB is at 4:30pm on March 31, 2022. Bids are still due at 2:30pm on March 31, 2022.

REMINDER: All proposals are due to the Weathersfield Town Offices no later than 2:30pm on Thursday, March 31, 2022.

Public Bid Opening will be at 4:30pm on March 31, 2021 at the Weathersfield Town Hall.